



GENERAL NOTES:

1. MINIMUM COVER BELOW STREET GRADE AT THE PLUGGED END OF THE SEWER SERVICE SHALL BE SET TO MAXIMIZE COVER, EXCEPT WHERE THE INVERT ELEVATIONS ARE GIVEN ON THE DRAWINGS.
2. WHEN THE SEWER MAIN AND SEWER SERVICE LINES ARE INSTALLED UNDER ONE CONTRACT, TEE FITTINGS ONLY SHALL BE PROVIDED FOR THE SERVICE LINES.
3. SERVICES LINES INSTALLED BEFORE EXFILTRATION TESTING OF THE SEWER SHALL PASS EXFILTRATION TESTS.
4. SEWER SERVICE LINES SHALL BE INSTALLED WHERE SHOWN ON THE DRAWINGS OR AS SPECIFIED BY THE ENGINEER.
5. INSTALL #14 TRACE WIRE ALONG ALL SERVICE LINES.



APPROVED	REVISIONS

CITY OF HAMILTON DEPARTMENT OF PUBLIC WORKS
TYPICAL SEWER SERVICE
HC. 20.02.001

PUBLIC WORKS
DIRECTOR

DATE